

УТВЕРЖДАЮ
Директор АО «Трансэнерго»



В.В. Пряхин

УТВЕРЖДАЮ
Глава Снежинского городского округа




И.И. Сапрыкин

Расчетный график температур теплоносителя в системе теплоснабжения от котельной города.

t_n	$T_1=150$	$T_1=105$ для жилпоселка №2	$T_3=95$	$T_2=70$ для города	T_2 для жилпоселка №2
8	65	60	50	43	49
7	65	60	50	43	49
6	65	60	49	42	48
5	65	60	49	42	48
4	65	60	48	41	48
3	65	60	48	41	47
2	65	60	48	40	47
1	66	60	48	40	47
0	69	60	50	41	46
-1	71	60	51	42	46
-2	74	60	53	43	46
-3	76	60	54	44	46
-4	79	60	56	45	45
-5	81	62	57	46	46
-6	84	64	59	47	47
-7	86	65	60	48	48
-8	89	67	61	49	49
-9	91	68	63	50	50
-10	94	70	64	51	51
-11	96	71	65	51	52
-12	98	73	67	52	53
-13	101	74	68	53	54
-14	103	76	69	54	54
-15	106	77	71	55	55
-16	108	79	72	56	56
-17	110	80	73	57	57
-18	111	81	73	56	57
-19	111	81	73	56	57
-20	111	81	73	55	56
-21	111	81	72	55	56
-22	111	81	72	54	56
-23	111	81	72	54	55
-24	111	81	71	53	55
-25	111	81	71	53	55
-26	111	81	71	52	54
-27	111	81	70	52	54
-28	111	81	70	51	54
-29	111	81	69	51	54
-30	111	81	69	50	53
-31	111	81	69	50	53
-32	111	81	68	49	53
-33	111	81	68	48	52
-34	111	81	68	48	52

Согласовано:
Заместитель директора АО «Трансэнерго»



А.С. Пульников