



Утверждаю
Директор МКП "Энергетик"
Д.В. Гаврилов

Температурный график газовой котельной МАУ ДОЦ "Орлёнок"

t нар. возд. °С	Подающий трубопровод			Обратный трубопровод
	1 скорость	2 скорость	3 скорость	
	насоса	насоса	насоса	
8	41	40	38	
7	43	41	40	33
6	44	42	41	34
5	46	44	42	35
4	48	45	43	36
3	50	47	44	37
2	52	48	45	38
1	53	49	46	39
0	55	51	48	40
-1	57	52	49	41
-2	58	54	51	42
-3	59	55	53	43
-4	60	55	54	44
-5	62	57	56	44
-6	63	59	57	45
-7	65	61	58	46
-8	67	62	60	47
-9	68	63	61	48
-10	70	65	63	49
-11	72	66	64	50
-12	73	67	66	51
-13	75	69	67	52
-14	76	71	68	52
-15	78	73	70	53
-16	79	74	71	54
-17	81	75	73	55
-18	83	77	74	56
-19	84	78	75	57
-20	85	80	77	58
-21	86	81	78	59
-22	87	83	79	60
-23	89	84	81	60
-24	90	85	82	61
-25	92	86	83	62
-26	93	87	85	63
-27	95	88	86	64
-28	96	90	87	64
-29	98	91	89	65
-30	99	92	90	66
-31	101	93	91	67
-32	102	94	92	68
-33	104	95	93	68
-34	105	97	95	69
				70



ОЛЕНА ВЕРНА
ДИРЕКТОР
Д.В. ГАВРИЛОВ